



Tallapoosa County Building Department
Todd Flurry, Building Inspector
125 North Broadnax St.
Room # 12
Dadeville, Alabama 36853

ATTENTION:

Before we can approve a Temp/Perm Power or as sometimes called a “pre -perm” the following must be completed:

Ceilings and Wall coverings must be in place.

All Switches, Plugs, Disconnects, and Devices must be installed.

The Majority of the light fixtures must be installed.

Thank You!